

8-33 FIRE PROTECTION EQUIPMENT

SECTION:

8-33-010: Marking Fire Sprinkler Control Valve Rooms

8-33-020: Marking Sprinkler Systems - Fire Department Connections

8-33-030: Marking Standpipe Systems - Fire Department Connections

8-33-040: Marking Fire Alarm Control Panel Rooms

8-33-010: Marking Fire Sprinkler Control Valve Rooms: Rooms containing fire sprinkler control valves and risers shall be labeled with approved signs that are red in color with white letters. Signs shall read "FIRE SPRINKLER CONTROL VALVE." Letters shall be a minimum of one (1) inch in size. Signs on exterior locations shall be made of all-weather materials.

8-33-020: Marking Sprinkler Systems - Fire Department Connections: Fire sprinkler systems fire department connections (FDC) shall be marked with approved building identifier numbers/letters and painted red in color for emergency identification purposes.

8-33-030: Marking Standpipe Systems - Fire Department Connections: Standpipe system fire department connections (FDC) shall be marked with approved building identifier numbers/letters and painted safety yellow in color for emergency identification purposes.

8-33-040: Marking Fire Alarm Control Panel Rooms: Rooms containing fire alarm control panels shall be labeled with approved signs that are red in color with white letters. Signs shall read "FIRE ALARM CONTROL PANEL." Letters shall be a minimum of one (1) inch in size. Signs on exterior locations shall be made of all-weather materials.